



Precision 10KV High Voltage Interface Specifications

The Precision Single Channel High Voltage Interface (10kV HVI-SC) is an attachment for any Precision test system. The 10kV HVI-SC will control the connection of a single High Voltage Amplifier to the sample under test protecting against any latent charge remaining on the test sample. The HVI has two primary functions. First, it acts as a signal router, sending stimulation voltages from the tester to the HVA while connecting the output of the HVA to the sample. The return signal from the sample is also routed through the HVI on its way back to the tester for analysis. The second primary function of the HVI is to provide protection to the user from the high voltages present during and after tests. The maximum voltage rating for the Precision HVI-SC is 10KV.



During normal operation, when a test is not being performed, the high voltage DRIVE and RETURN outputs of the Precision HVI-SC are disconnected from the HVA and connected directly to earth ground preventing any latent voltage from remaining on the sample.

The sample is connected to the HVA and the tester only during the execution of hardware task in the Vision operating system. High voltage isolation relays when execute the switch matrix function are rated for 15KV.

Safety

High Voltage ceramic samples routinely breakdown during high voltage testing creating a strong chance of damage to the test system measurement circuits. To prevent this damage, the HVI has four layers of protection. The first is a voltage limiting circuit on the HVI RETURN input prevents the HV RETURN from exceeding 2.1 Volts.

For voltages greater than 2.1V, all current is routed to the earth ground and away from the tester inputs. This prevents the excess voltage and current during a sample breakdown from exceeding the current canceling capability of the virtual ground circuitry of the tester input. The second form of protection is a slower circuit in the HVI RETURN input that will open the isolation relays and ground the sample if the shorted condition persists for longer than 14ms. The third safety layer for the HVI lies in its I2C communications channel with the Precision tester. Through this communications interface, the tester can control the state of the HVI and detect a fault condition. As well, the High Voltage Amplifier must have an Identification Module (ID Module) attached that holds the specifications of the HVA.

The Vision operating system will not allow a test to proceed if the specifications of the HVA do not match those specified for a test. This feature prevents inadvertent application of excess high voltage to the sample. For users employing a safety enclosure, 10KV HVI-SC has a safety interlock system that allows the researcher to connect the HVI to a door, lid, or other physical barrier. All high voltage functions are disabled unless the safety interlock is activated.



HVI2 Specifications:

- » Channels:
1 Channel
**Maximum International Voltage Rating:
10KV (AC)**
- » Maximum International Voltage Rating:
10KV (AC)
- » Power:
**100V to 240V,
50 to 60Hz**
- » High Speed Protection Current Rating:
10 Amps
- » High Speed Protection Trigger Voltage
2.1V
- » Low Speed Protection Delay Time
14ms
- » Isolation Relay Switchable Voltage
12KV
- » International Insulation Rating:
>40KV DC 4

Note

The DC voltage rating for high voltage insulation does not take into account RF coupling of high voltage AC Signals through the insulation to grounded objects. We have found that high voltage wire insulation must be de-rated by approximately a factor of four for the high voltage frequency levels used in Radiant's testers.

For instance, to run a 10KV triangle wave at 1KHz requires insulation on the test cables with a DC rating of at least 40KV. Radiant normally supplies its customers with high voltage cables having ratings greater than 40KV for use with the 10KV HVI. Cables with ratings higher than 25KV can easily be recognized. They are encased in a sheath of rubber tubing. Of necessity, external panel mounted connectors have metal contacts exposed to ambient air deep inside the connector barrel.

These exposed metal contacts will create corona in dry air (40% humidity for frequencies above 50Hz at voltage greater than 8KV). The corona is not exposed outside the interior confines of the connector and is not a safety issue. Nevertheless, Radiant recommends the use of silicon paste (Dow corning 5 compound) inside the HV connectors of the HVI during very high voltage operation to prevent arcing between the connector and the plug from oxidizing the contact.

ATTENTION:

The low impedance (<25 ohms) Earth Ground connection to the Test System must be verified by licensed personnel in order for Radiant Technologies, Inc. One year parts and labor warranty to be valid.